

Anex

Kolink Enclave 500W (#2)

Lab ID#: KL50001613
Receipt Date: Jun 11, 2019
Test Date: Feb 28, 2020

Report: 20PS1613A

Report Date: Mar 4, 2020

DUT INFORMATION

Brand	Kolink
Manufacturer (OEM)	Kolink
Series	Enclave
Model Number	KL-G500FM
Serial Number	KOL-016-0619000002
DUT Notes	

DUT SPECIFICATIONS

Rated Voltage (Vrms)	100-240
Rated Current (Arms)	
Rated Frequency (Hz)	50-60
Rated Power (W)	500
Type	ATX12V
Cooling	120mm Rifle Bearing Fan (EFS-12E12H)
Semi-Passive Operation	X
Cable Design	Fully Modular

POWER SPECIFICATIONS

Rail		3.3V	5V	12V	5VSB	-12V
Max. Power	Amps	16	16	41	3	0.5
	Watts	100		492	15	6
Total Max. Power (W)		500				

CABLES AND CONNECTORS

Modular Cables

Description	Cable Count	Connector Count (Total)	Gauge	In Cable Capacitors
ATX connector 20+4 pin (500mm)	1	1	18-22AWG	No
4+4 pin EPS12V (650mm)	1	1	18AWG	No
6+2 pin PCIe (600mm+100mm)	1	2	18AWG	No
SATA (450mm+120mm+120mm)	1	3	20AWG	No
SATA (450mm) / 4 pin Molex (+120mm+120mm)	2	2 / 4	18-20AWG	No

All data and graphs included in this test report can be used by any individual on the following conditions:

- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

PAGE 1/16

Anex

Kolink Enclave 500W (#2)

General Data	
Manufacturer (OEM)	Kolink
PCB Type	Double Sided
Primary Side	
Transient Filter	5x Y caps, 3x X caps, 2x CM chokes
Inrush Protection	NTC Thermistor & Relay
Bridge Rectifier(s)	1x GBU1506 (600V, 15A @ 100°C)
APFC MOSFETS	2x Advanced Power AP65SL380AI (650V, 6.5A @ 100°C, 0.380hm)
APFC Boost Diode	1x Infineon IDH06G65C6 (650V, 6A @ 145°C)
Hold-up Cap(s)	1x Teapo (420V, 330uF, 2000h @ 105°C, LG)
Main Switchers	4x Great Power GPT10N50AD (500V, 9.7A, 0.70hm)
APFC Controller	On Semiconductor NCP1654
Resonant Controllers	Champion CM6901T6
Topology	Primary side: Full-Bridge & LLC converter Secondary side: Synchronous Rectification & DC-DC converters
Secondary Side	
+12V MOSFETS	4x Nexperia PSMN2R6-40YS (40V, 100A @ 100°C, 5.3mOhm @ 175°C)
5V & 3.3V	DC-DC Converters: 4x Excellance MOS EMB09N03HR (30V, 35A @ 100°C, 9.5mOhm) PWM Controllers: ANPEC APW7159
Filtering Capacitors	Electrolytics: 10x Teapo (1-3,000h @ 105°C, SC), 1x CapXon (2-5,000h @ 105°C, KF) Polymers: CapXon
Supervisor IC	IN1S313I-DAG & UTC393
Fan Model	DWPH EFS-12E12H (120mm, 12V, 0.50A, Rifle Bearing Fan)
5VSB Circuit	
Rectifier	1x MBR2045CT SBR (45V, 20A)
Standby PWM Controller	Infineon ICE2QR4765

All data and graphs included in this test report can be used by any individual on the following conditions:

- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

PAGE 2/16

Anex

Kolink Enclave 500W (#2)

RESULTS

Temperature Range (°C /°F)	30-32 / 86-89.6
ErP Lot 3/6 Ready	ErP Lot 6 2010: ✓ ErP Lot 6 2013: ✓ ErP Lot 3 2014 & CEC: Partially
(EU) No 617/2013 Compliance	✓

115V

Average Efficiency	88.654%
Efficiency With 10W (≤500W) or 2% (>500W)	52.344
Average Efficiency 5VSB	79.434%
Standby Power Consumption (W)	0.0869220
Average PF	0.986
Avg Noise Output	28.05 dB(A)
Efficiency Rating (ETA)	GOLD
Noise Rating (LAMBDA)	A-

230V

Average Efficiency	90.577%
Average Efficiency 5VSB	77.636%
Standby Power Consumption (W)	0.1349660
Average PF	0.930
Avg Noise Output	29.70 dB(A)
Efficiency Rating (ETA)	GOLD
Noise Rating (LAMBDA)	A-

TEST EQUIPMENT

Electronic Loads	Chroma 63601-5 x4 Chroma 63600-2 x2 63640-80-80 x20 63610-80-20 x2
AC Sources	Chroma 6530, Keysight AC6804B
Power Analyzers	N4L PPA1530 x2
Sound Analyzer	Bruel & Kjaer 2270 G4
Microphone	Bruel & Kjaer Type 4955-A
Data Loggers	Picoscope TC-08 x2, Labjack U3-HV x2
Tachometer	UNI-T UT372 x2
Digital Multimeter	Keysight U1273AX, Fluke 289, Keithley 2015 - THD
UPS	CyberPower OLS3000E 3kVA x2

HOLD-UP TIME & POWER OK SIGNAL (230V)

Hold-Up Time (ms)	18.5
AC Loss to PWR_OK Hold Up Time (ms)	14.7
PWR_OK Inactive to DC Loss Delay (ms)	3.8

All data and graphs included in this test report can be used by any individual on the following conditions:


- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

PAGE 3/16

EFFICIENCY UNDER HIGH AMBIENT TEMPERATURE

Efficiency: Kolink KL-G500FM

Ambient: 37°C - 47°C (98.6°F - 116.6°F)




INFO

The PSU's efficiency under high ambient temperatures with 115V and 230V input. For this graph the results of the 10-110% load regulation table are used

5VSB EFFICIENCY

5VSB Efficiency: Kolink KL-G500FM

Ambient: 34°C - 36°C (93.2°F - 96.8°F)



INFO

This graph depicts the efficiency levels of the 5VSB rail with 115V and 230V input

All data and graphs included in this test report can be used by any individual on the following conditions:

- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

Anex

Kolink Enclave 500W (#2)

5VSB EFFICIENCY -115V (ERP LOT 3/6 & CEC)

Test #	5VSB	DC/AC (Watts)	Efficiency	PF/AC Volts
1	0.045A	0.230	69.697%	0.043
	5.119V	0.330		115.14V
2	0.090A	0.461	73.175%	0.080
	5.117V	0.630		115.14V
3	0.550A	2.808	77.698%	0.312
	5.105V	3.614		115.14V
4	1.000A	5.094	80.563%	0.394
	5.093V	6.323		115.15V
5	1.500A	7.621	80.441%	0.441
	5.079V	9.474		115.15V
6	3.000A	15.117	78.632%	0.497
	5.039V	19.225		115.14V

5VSB EFFICIENCY -230V (ERP LOT 3/6 & CEC)

Test #	5VSB	DC/AC (Watts)	Efficiency	PF/AC Volts
1	0.045A	0.230	57.644%	0.016
	5.118V	0.399		230.33V
2	0.090A	0.461	65.205%	0.028
	5.117V	0.707		230.33V
3	0.550A	2.808	74.940%	0.134
	5.105V	3.747		230.36V
4	1.000A	5.094	78.177%	0.208
	5.093V	6.516		230.36V
5	1.500A	7.620	79.226%	0.268
	5.079V	9.618		230.35V
6	3.001A	15.117	79.921%	0.360
	5.038V	18.915		230.34V

All data and graphs included in this test report can be used by any individual on the following conditions:

- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

PAGE 5/16

Anex

Kolink Enclave 500W (#2)


115V

All data and graphs included in this test report can be used by any individual on the following conditions:

- › It should be mentioned that the test results are provided by Cybenetics
- › The link to the original test results document should be provided in any case

PAGE 6/16


EFFICIENCY GRAPH 115V



INFO

This graph depicts the PSU's efficiency throughout its entire operational range. For the generation of the efficiency and noise graphs we set our loaders to auto mode through our custom-made software before trying thousands of possible load combinations

NOISE GRAPH 115V



INFO

The PSU's noise in its entire operational range and under 30-32 °C ambient is depicted in this graph. The X axis represents the load on the +12V rail(s) while the Y axis is the load on the minor rails

All data and graphs included in this test report can be used by any individual on the following conditions:


- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

Anex

Kolink Enclave 500W (#2)

VAMPIRE POWER -115V

Power - 25/02/2020 - 12:00



INFO

This graph is generated by the PPA Standby Power Analysis software which takes full control of the power analyzer during the whole procedure. This application features all of the EN50564 & IEC62301 test limits for standby power software testing

All data and graphs included in this test report can be used by any individual on the following conditions:

- › It should be mentioned that the test results are provided by Cybenetics
- › The link to the original test results document should be provided in any case

PAGE 8/16

Anex

Kolink Enclave 500W (#2)

10-110% LOAD TESTS 115V

Test #	12V	5V	3.3V	5VSB	DC/AC (Watts)	Efficiency	Fan Speed (RPM)	PSU Noise (dB[A])	Temps (In/Out)	PF/AC Volts
1	2.342A	1.993A	1.951A	0.984A	50.002	81.255%	773	14.8	40.10°C	0.952
	12.124V	5.021V	3.382V	5.083V	61.537				42.98°C	115.16V
2	5.706A	2.994A	2.936A	1.184A	100.027	87.087%	779	14.9	40.23°C	0.980
	12.113V	5.011V	3.373V	5.070V	114.859				43.97°C	115.16V
3	9.414A	3.498A	3.432A	1.384A	149.983	89.185%	784	15.1	41.07°C	0.987
	12.103V	5.002V	3.365V	5.058V	168.170				45.15°C	115.14V
4	13.133A	4.005A	3.933A	1.586A	200.024	89.652%	1446	33.1	41.74°C	0.985
	12.093V	4.994V	3.357V	5.046V	223.111				46.55°C	115.13V
5	16.516A	5.018A	4.927A	1.789A	250.054	89.746%	1798	40.0	42.39°C	0.987
	12.082V	4.984V	3.348V	5.032V	278.623				47.71°C	115.13V
6	19.898A	6.034A	5.931A	1.993A	300.007	89.751%	1808	40.0	42.43°C	0.990
	12.071V	4.974V	3.339V	5.018V	334.266				48.53°C	115.13V
7	23.298A	7.054A	6.936A	2.199A	350.083	89.519%	1820	40.0	43.21°C	0.992
	12.060V	4.963V	3.330V	5.004V	391.072				49.86°C	115.13V
8	26.702A	8.003A	7.950A	2.405A	399.748	89.187%	1823	40.0	43.70°C	0.993
	12.048V	4.953V	3.321V	4.990V	448.215				50.82°C	115.12V
9	30.512A	8.598A	8.451A	2.409A	449.815	88.837%	1824	40.0	44.65°C	0.994
	12.038V	4.944V	3.313V	4.983V	506.337				52.48°C	115.12V
10	34.099A	9.121A	8.989A	3.026A	499.832	88.303%	1832	39.9	45.35°C	0.995
	12.027V	4.935V	3.305V	4.958V	566.040				53.39°C	115.12V
11	38.291A	9.134A	9.007A	3.030A	549.855	87.872%	1833	39.9	46.63°C	0.995
	12.017V	4.927V	3.298V	4.952V	625.744				55.42°C	115.13V
CL1	0.117A	11.999A	12.000A	0.000A	101.443	82.277%	1811	40.0	42.30°C	0.985
	12.099V	4.986V	3.350V	5.082V	123.295				47.29°C	115.16V
CL2	41.009A	1.001A	1.000A	1.000A	507.030	89.391%	1824	40.0	45.92°C	0.995
	12.039V	4.959V	3.327V	5.032V	567.206				53.76°C	115.12V

All data and graphs included in this test report can be used by any individual on the following conditions:

- › It should be mentioned that the test results are provided by Cybenetics
- › The link to the original test results document should be provided in any case

PAGE 9/16

Anex

Kolink Enclave 500W (#2)

20-80W LOAD TESTS 115V

Test #	12V	5V	3.3V	5VSB	DC/AC (Watts)	Efficiency	Fan Speed (RPM)	PSU Noise (dB[A])	PF/AC Volts
1	1.224A	0.497A	0.487A	0.196A	19.991	66.371%	751	13.8	0.863
	12.121V	5.032V	3.391V	5.112V	30.120				115.16V
2	2.448A	0.994A	0.973A	0.392A	39.981	79.639%	758	14.1	0.939
	12.128V	5.026V	3.386V	5.103V	50.203				115.16V
3	3.675A	1.494A	1.464A	0.589A	60.010	83.979%	769	14.6	0.967
	12.124V	5.021V	3.382V	5.094V	71.458				115.16V
4	4.898A	1.994A	1.953A	0.787A	79.959	86.191%	772	14.8	0.981
	12.119V	5.016V	3.378V	5.085V	92.770				115.16V

RIPPLE MEASUREMENTS 115V

Test	12V	5V	3.3V	5VSB	Pass/Fail
10% Load	20.50mV	4.00mV	12.60mV	6.40mV	Pass
20% Load	30.70mV	4.20mV	12.70mV	6.80mV	Pass
30% Load	41.30mV	4.40mV	12.40mV	6.40mV	Pass
40% Load	48.20mV	4.90mV	13.00mV	6.40mV	Pass
50% Load	50.20mV	5.20mV	15.10mV	7.10mV	Pass
60% Load	41.40mV	4.90mV	13.60mV	7.30mV	Pass
70% Load	37.50mV	5.10mV	13.70mV	7.50mV	Pass
80% Load	33.90mV	5.10mV	14.60mV	7.30mV	Pass
90% Load	33.60mV	6.00mV	17.00mV	8.10mV	Pass
100% Load	47.10mV	7.00mV	18.70mV	9.50mV	Pass
110% Load	48.80mV	7.30mV	18.90mV	9.70mV	Pass
Crossload1	39.00mV	5.90mV	17.50mV	7.40mV	Pass
Crossload2	45.30mV	6.10mV	14.30mV	8.70mV	Pass

All data and graphs included in this test report can be used by any individual on the following conditions:

- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

PAGE 10/16

Anex

Kolink Enclave 500W (#2)


230V

All data and graphs included in this test report can be used by any individual on the following conditions:

- › It should be mentioned that the test results are provided by Cybenetics
- › The link to the original test results document should be provided in any case

PAGE 11/16


EFFICIENCY GRAPH 230V



INFO

This graph depicts the PSU's efficiency throughout its entire operational range. For the generation of the efficiency and noise graphs we set our loaders to auto mode through our custom-made software before trying thousands of possible load combinations

NOISE GRAPH 230V



INFO


The PSU's noise in its entire operational range and under 30-32 °C ambient is depicted in this graph. The X axis represents the load on the +12V rail(s) while the Y axis is the load on the minor rails

All data and graphs included in this test report can be used by any individual on the following conditions:

- › It should be mentioned that the test results are provided by Cybenetics
- › The link to the original test results document should be provided in any case

VAMPIRE POWER -230V

Power - 25/02/2020 - 12:00



INFO

This graph is generated by the PPA Standby Power Analysis software which takes full control of the power analyzer during the whole procedure. This application features all of the EN50564 & IEC62301 test limits for standby power software testing

All data and graphs included in this test report can be used by any individual on the following conditions:

- › It should be mentioned that the test results are provided by Cybenetics
- › The link to the original test results document should be provided in any case

Anex

Kolink Enclave 500W (#2)

10-110% LOAD TESTS 230V

est #	12V	5V	3.3V	5VSB	DC/AC (Watts)	Efficiency	Fan Speed (RPM)	PSU Noise (dB[A])	Temps (In/Out)	PF/AC Volts
1	2.342A	1.992A	1.952A	0.984A	49.996	82.543%	776	14.8	40.72°C	0.738
	12.123V	5.021V	3.382V	5.083V	60.570				44.32°C	230.29V
2	5.706A	2.994A	2.934A	1.184A	100.014	88.593%	782	15.0	40.85°C	0.857
	12.112V	5.011V	3.373V	5.070V	112.892				44.75°C	230.28V
3	9.414A	3.499A	3.432A	1.384A	149.970	90.634%	787	15.1	41.55°C	0.910
	12.101V	5.002V	3.365V	5.058V	165.467				45.89°C	230.30V
4	13.134A	4.005A	3.932A	1.586A	200.009	91.326%	1400	32.9	41.88°C	0.937
	12.091V	4.994V	3.358V	5.045V	219.006				46.80°C	230.30V
5	16.517A	5.018A	4.928A	1.789A	250.042	91.391%	1806	40.0	42.19°C	0.952
	12.080V	4.984V	3.349V	5.032V	273.595				47.63°C	230.31V
6	19.901A	6.034A	5.932A	1.993A	300.000	91.563%	1816	40.0	42.57°C	0.962
	12.069V	4.973V	3.339V	5.018V	327.644				48.61°C	230.31V
7	23.300A	7.055A	6.938A	2.199A	350.073	91.535%	1824	40.0	43.20°C	0.968
	12.058V	4.963V	3.330V	5.004V	382.448				49.81°C	230.32V
8	26.706A	8.001A	7.950A	2.405A	399.725	91.418%	1824	40.0	43.40°C	0.973
	12.046V	4.953V	3.320V	4.990V	437.250				50.40°C	230.32V
9	30.516A	8.598A	8.451A	2.409A	449.801	91.304%	1834	39.9	45.30°C	0.977
	12.036V	4.944V	3.313V	4.983V	492.641				52.82°C	230.32V
10	34.107A	9.120A	8.989A	3.026A	499.846	91.039%	1835	39.9	45.44°C	0.978
	12.025V	4.935V	3.304V	4.958V	549.045				53.70°C	230.32V
11	38.300A	9.134A	9.007A	3.030A	549.878	90.894%	1841	39.9	46.59°C	0.980
	12.015V	4.927V	3.297V	4.952V	604.963				55.35°C	230.33V
CL1	0.117A	12.000A	11.999A	0.000A	101.443	83.653%	1824	40.0	42.28°C	0.869
	12.098V	4.986V	3.350V	5.081V	121.267				47.80°C	230.34V
CL2	41.013A	1.000A	0.999A	1.000A	507.025	92.103%	1833	39.9	45.40°C	0.978
	12.038V	4.958V	3.326V	5.031V	550.495				53.64°C	230.34V

All data and graphs included in this test report can be used by any individual on the following conditions:

- > It should be mentioned that the test results are provided by Cybenetics
- > The link to the original test results document should be provided in any case

PAGE 14/16

Anex

Kolink Enclave 500W (#2)

20-80W LOAD TESTS 230V

Test #	12V	5V	3.3V	5VSB	DC/AC (Watts)	Efficiency	Fan Speed (RPM)	PSU Noise (dB[A])	PF/AC Volts
1	1.223A	0.496A	0.487A	0.196A	19.984	69.505%	744		

RIPPLE MEASUREMENTS 230V

Test	12V	5V	3.3V	5VSB	Pass/Fail
10% Load	27.10mV	4.20mV	11.50mV	6.90mV	Pass
20% Load	40.80mV	4.10mV	12.40mV	7.30mV	Pass
30% Load	50.60mV	5.00mV	12.70mV	6.90mV	Pass
40% Load	56.60mV	5.00mV	13.00mV	7.30mV	Pass
50% Load	58.60mV	4.90mV	13.10mV	7.00mV	Pass
60% Load	49.20mV	4.90mV	12.70mV	7.50mV	Pass
70% Load	42.30mV	5.40mV	13.00mV	7.70mV	Pass
80% Load	39.10mV	5.70mV	15.90mV	8.30mV	Pass
90% Load	36.80mV	6.30mV	17.90mV	8.60mV	Pass
100% Load	49.40mV	7.00mV	17.20mV	10.10mV	Pass
110% Load	50.70mV	7.30mV	18.00mV	10.20mV	Pass
Crossload1	46.70mV	6.20mV	18.30mV	7.80mV	Pass
Crossload2	47.20mV	6.40mV	14.50mV	8.90mV	Pass

All data and graphs included in this test report can be used by any individual on the following conditions:

- › It should be mentioned that the test results are provided by Cybenetics
- › The link to the original test results document should be provided in any case

PAGE 15/16

